

Addendum #2

Date: October 15, 2025
Project: Legislative Hall Parking Garage
OMB/DFM Contract No. MJ1002000071

The work herein shall be considered part of the bid documents for the referenced project and carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents without change in Contract Sum or Contract Time. Acknowledge receipt of addendum on the bid form as indicated.

General:

1. Products equal to the basis of design must be submitted for prior approval before bidding and shall include proposed product data for review for all of the following
 - a. Lighting
 - b. Thin Brick
 - c. Cornices and Trim
 - d. Roof Shingles
2. Substitution requests must follow the requirements outlined in specification section 01 25 00 – Substitution Procedures.

RFIs:

1. Section 263213, 1.04 X. tools and a tool box are not available option from generator manufacturer. Confirm tools and tool box can be excluded from specifications?
 - a. **Response: Confirmed.**
2. Section 263213, 2.01 A. Kohler Power Systems is now named Rehlko. Please acknowledge change in name from Kohler Power Systems to Rehlko Power Systems?
 - a. **Response: Acknowledged.**
3. Section 263213, 2.02 D. 4. Confirm shall new 225A generator breaker be thermal magnetic or electronic LSI type?
 - a. **Response: Thermal magnetic.**
4. Section 263213, 2.02 D. 4. Confirm shall new 225A generator breaker be 80% rated or 100% rated?
 - a. **Response: 80%**
5. Section 263213, 2.03 C. 5. Is battery heater required as no power circuit is shown on electrical plans for it?
 - a. **Response: Battery heater is required. Circuit shall be added to the electrical plans.**

6. Section 263213, 2.05 C. specifies to provide two (2) remote annunciators for the 150 KW generator. Confirm is this required or is only one (1) remote annunciator acceptable?
 - a. **Response: (1) is acceptable.**
7. Section 263213, 2.06 I. enclosure space heater is not an available option for a 150 KW generator confirm it can be excluded from specifications? Generator will have block heater and battery charger only per drawings.
 - a. **Response: Space heater can be excluded.**
8. Section 263213, 2.08 J. specifies the 150 KW generator to have a diesel oxidation catalyst. This is not required by Kohler as the unit is already EPA Tier 3 certified for emergency standby generator. Please confirm Diesel Oxidation Catalyst can be excluded from generator specifications?
 - a. **Response: Confirmed, diesel oxidation catalyst can be excluded.**
9. Section 263213, 2.09 specifies walkway platform with stairs and hand rails however the drawing A-123 does not show any walkway platforms for the new 150 KW generator. Confirm the walkway platforms can be excluded for this small 150 KW generator as it is not required by manufacturer and not shown on architectural or electrical plans. Also Kohler GM74974-TPLX is not an available part number for a 150 KW generator as its not offered for a small generator. The walkway platforms appear to be more so for the future larger generator package and not this 150 KW.
 - a. **Response: Confirmed, walkway platforms shall be excluded for the 150KW generator.**
10. Section 263600, 2.01 ATS manufacturers does not list KOHLER (REHLKO) as approved for the ATS. Can they be added to the specifications as acceptable?
 - a. **Response: Kohler / Rehlko is an acceptable manufacturer for the ATS.**
11. Section 263600, 2.01 A. specifies 4-pole ATS while drawing E-600 specifies 3P confirm shall new ATS be 3-pole solid neutral or 4-pole switched neutral?
 - a. **Response: Provide 3 pole solid neutral.**
12. Section 263600, 2.01 A. and 2.02 E. 1. specifies basis of design ASCO 4000 Series. 4000 Series ATS are obsolete and no longer available. Confirm shall new ATS be ASCO 300 Series or ASCO 7000 Series type?
 - a. **Response: Basis of design shall be ASCO 300 series.**
13. Section 263600, 2.02 M. confirm new 260A ATS does not need to be service entrance rated as there is a disconnect ahead of the ATS and it is not directly connected to the service entrance?
 - a. **Response: Confirmed.**
14. Drawing A-201 and A-203 (South Elevation; CL 7). A-203 shows (3) openings on CL 7 that are not shown on A-201. Are these (3) openings required on the exterior wall panels?

a. Response: No, disregard the (3) openings on A-203 CL 7.

15. RFI- Spec Section 03 41 00/ 2.9 Thin Brick Veneer.
Spec Section 04 26 16 Adhered Masonry Veneer/ Part 2/ 2.01 Thin Brick

Please clarify specific name and percentage of each type brick listed as “Dover Blend”, for each manufacturer.

- a. Endicott – 3- color blend 60% Burgundy Sands No Black, 20% Merlot Sands No Black,20% Autumn Sands w/Black Heritage**
METROBRICK – 3-color blend 70%#365, 25% #310, 5% #84F
General Shale – 2- color blend 90% Schoolhouse, 10% Mesquite

Drawing Revisions:

1. E-602
 - a. Added a circuit for the generator battery charger. Added wire and conduit sizes for the generator block heater. Added a note to the bottom of PNL-EPL schedule.

Attachments:

1. Drawings indicated in the drawing revisions section above.

END