



5000 PSI AIR HEAT EXCHANGER

Requirements Document
B1215 Steam Plant Heat-Exchanger
Rev 0

5000 PSI AIR HEAT EXCHANGER
Requirements Document
B1215 Steam Plant Heat-Exchanger

Table of Contents

1.0 SCOPE

2.0 GENERAL

2.1 BASIC DESIGN

2.2 SUBMITTALS

2.2.1 Proposal Information

2.2.2 Shop Drawings

2.2.3 Product Data

2.2.4 Test Reports

2.2.5 Certificates

2.3 QUALITY ASSURANCE

2.4 DELIVERY, STORAGE, AND HANDLING

2.5 SPARE PARTS

3.0 PRODUCTS

3.1 MATERIALS AND EQUIPMENT

3.1.1 Standard Products

3.1.2 Nameplates

3.1.3 Asbestos Prohibition

3.1.4 Body, Stationary Head, Cover

3.1.5 Body Flanges, Tube Sheet, Tubes

3.1.6 Connections: Hub Connectors, Flanges, Couplings

3.1.7 Gaskets for Flanges

3.1.8 Studs and Nuts

3.2 HEAT EXCHANGERS

3.2.1 Type

3.2.2 General Construction

3.2.3 Performance

3.2.4 Dimensions

3.3 SYSTEM EQUIPMENT AND ACCESSORIES

3.3.1 Lifting and Support Systems

3.3.2 Vent Connection

3.3.3 Coating/Paint System

4.0 EXECUTION

4.1 Connections

4.2 Testing and Cleaning

4.3 Pressure Testing

4.4 Cleaning

Appendix A

Heat Exchanger Data Sheet

5000 PSI AIR HEAT EXCHANGER
Requirements Document
B1215 Steam Plant Heat-Exchanger

1.0 SCOPE

This document provides the requirements for the procurement of one heat-exchanger that will serve as a Joules-Thompson heater for the 5000 psi Air Reducing Station at the Steam Plant, B1215.

2.0 GENERAL

2.1 BASIC DESIGN

2.1.1 The heat exchanger shall be:

- 2.1.1.1 designed to heat air (5000 psig design, 4250 psig maximum operation, 2800 psig minimum operation) with 125 psig saturated steam metered by a control valve. See the data sheet in Appendix A for performance requirements.
- 2.1.1.2 designed and stamped per ASME Section VIII Division 1 code and provided with a nameplate
- 2.1.1.3 designed per applicable ASTM and MSS SP standards or other applicable ASME codes
- 2.1.1.4 complimentarily designed to TEMA standards
- 2.1.1.5 provided with process connections per data sheet in Appendix A
- 2.1.1.6 provided with support saddles and lifting lugs per Appendix A
- 2.1.1.7 fabricated with new materials that conform to the Buy American Act

2.2 SUBMITTALS

Government (NASA) approval is required for submittals in each section herein:

2.2.1 Proposal Information

2.2.1.1 The vendor's proposal shall include the following:

- 2.2.1.1.1 completed datasheets, following those given in TEMA General Fabrication and Performance Information, Section 3, Figure G-5.2M Heat Exchanger Specification Sheet,
- 2.2.1.1.2 Following the data sheets included in Appendix A, a written statement indicating complete compliance of the new heat exchanger provided herein with datasheets in Appendix A.

2.2.1.2 The Vendor's proposal shall include drawings and sketches that are sufficient to describe the heat exchanger construction, to be provided as required in Appendix A.

2.2.1.3 Design features that are not fully defined by the nomenclature in TEMA, Section 1

2.2.1.4 The proposal shall include detailed description of all exceptions to the requirements herein.

2.2.1.5 The Vendor shall supply the following components:

- 2.2.1.5.1 Data and Information indicating compliance to specified requirements for bolts, nuts, and gaskets with torque requirements suitable for pressures and temperatures identified.

2.2.1.6 Identify the cost in dollars for the goods including all shipping and insurance to the point of delivery identified herein. The time for delivery of goods shall be identified in the Vendor's proposal.

5000 PSI AIR HEAT EXCHANGER
Requirements Document
B1215 Steam Plant Heat-Exchanger

2.2.2 Shop Drawings

2.2.2.1 On award of the work, the Vendor shall submit, for review by the Government, outline drawings for the heat exchanger. The drawings shall include at least the following information:

- 2.2.2.1.1 service, item number, project name and location, Government's order number, Vendor's shop order number, serial number, and other special identification numbers
- 2.2.2.1.2 design pressure, test pressure, design temperature, minimum design metal temperature (MDMT), and any restriction on testing or operation of the heat exchanger
- 2.2.2.1.3 maximum allowable working pressure (MAWP) in the corroded condition and at the design temperature for the shell side and tube side
- 2.2.2.1.4 connection sizes, location, orientation, projection, direction of flow and, if flanged, the rating and facing type
- 2.2.2.1.5 measurement instruments used and their calibration data
- 2.2.2.1.6 overall dimensions of the heat exchanger
- 2.2.2.1.7 mass of the heat exchanger, empty and full of water, and of any removable components with a mass greater than 60 lb
- 2.2.2.1.8 specified corrosion allowance for each side of the heat exchanger
- 2.2.2.1.9 references to the applicable code and the Government's specification
- 2.2.2.1.10 requirements for non-destructive examination (NDE)
- 2.2.2.1.11 requirements for material impact testing
- 2.2.2.1.12 requirements for surface preparation and painting
- 2.2.2.1.13 gasket materials, type and thickness
- 2.2.2.1.14 location and orientation of nameplates, lifting lugs, grounding clips or other attachments
- 2.2.2.1.15 location of the center of gravity of the heat exchanger (empty and full of water)

2.2.2.2 The review of shop drawing documents by the Government shall not relieve the Vendor and Original Equipment Manufacturer of the responsibility for meeting the requirements herein and the purchase order.

2.2.2.3 Information Required After Outline Drawings Are Reviewed:

- 2.2.2.3.1 The Vendor shall submit gasket details, including type and material, on a separate drawing. This drawing shall not be marked with any restrictions for use.

2.2.2.4 Upon receipt of the Government's review comments on the outline drawings, the Vendor shall submit copies of all detailed drawings for the Government's review. These shall fully describe the heat exchanger and shall include at least the following information:

- 2.2.2.4.1 complete bills of materials, including the material specification
- 2.2.2.4.2 special installation and maintenance instructions including lifting and handling.

2.2.2.5 After final review the Vendor shall revise all the required drawings, welding procedures, and submit each with the following text marked on every sheet separately and dated: "CERTIFIED FOR CONSTRUCTION."

2.2.2.6 Reports and Records

- 2.2.2.6.1 After the heat exchanger is completed, the Original Equipment Manufacturer shall furnish to the Government with the following documents in Adobe

5000 PSI AIR HEAT EXCHANGER
Requirements Document
B1215 Steam Plant Heat-Exchanger

Acrobat PDF searchable format and one hard copy, specified by the Government:

- 2.2.2.6.1.1 “as-built” datasheet, and Form U1 Manufacturer’s Data Report for Pressure Vessels; Form U-5 Manufacturer’s Data Report Supplementary Sheet; Photo of label plate; photo of serial number label plate; General Fabrication and Performance Information sheet in accordance with Figure G-5.2M Heat exchanger Specification Sheet TEMA;
- 2.2.2.6.1.2 all outline and detail drawings, marked “CERTIFIED AS-BUILT”;
- 2.2.2.6.1.3 certified mill test reports for all pressure parts, including tubes (each material test report shall be identified by a part number)
- 2.2.2.6.1.4 complete certified bill of materials suitable for obtaining all replacement parts, including quantity, description, material specification, and identification of each part
- 2.2.2.6.1.5 temperature charts of all postweld heat treatments, if applicable
- 2.2.2.6.1.6 completed manufacturer’s data report in accordance with the pressure design code
- 2.2.2.6.1.7 nameplate photo
- 2.2.2.6.1.8 non-destructive examination (NDE) map
- 2.2.2.6.1.9 all associated NDE reports, including radiographic, magnetic-particle, liquid-penetrant, ultrasonic, hardness, positive material identification (PMI), and any other reports as applicable
- 2.2.2.6.1.10 leak-test results
- 2.2.2.6.1.11 hydrostatic test records in the form of a chart or certification

2.2.3 Product Data

- 2.2.3.1 Gaskets
- 2.2.3.2 Studs and Nuts
- 2.2.3.3 Primer and final paint coatings

2.2.4 Test Reports

- 2.2.4.1 Testing Results
- 2.2.4.2 Cleaning

2.2.5 Certificates

- 2.2.5.1 Certificate of Shop Compliance
- 2.2.5.2 Certificate of Shop Inspection
- 2.2.5.3 Bill of Materials
- 2.2.5.4 Written certification from Original Equipment Manufacturer that all materials of construction are new, unused, and not remanufactured.

2.3 QUALITY ASSURANCE

Vendor shall act on behalf and provide Original Equipment Manufacturer’s material and goods. Vendor shall be responsible to respond to all purchase and specification requirements.

Procedures and welders must be qualified in accordance with the code under which the welding is specified to be accomplished.

5000 PSI AIR HEAT EXCHANGER
Requirements Document
B1215 Steam Plant Heat-Exchanger

Original Equipment Manufacturer shall submit written certification that all materials are new, unused, and not remanufactured.

2.4 DELIVERY, STORAGE, AND HANDLING

2.4.1 The goods shall be manufactured for:

NASA Langley Research Center
14 West Taylor Street
Building 1215
Hampton, Virginia 23681

2.4.2 Deliver the approved completed goods to:

NASA Langley Research Center
4 South Marvin Street
Building 1206
Hampton, Virginia 23681

2.4.3 NASA contact where all correspondence including shop drawings, data, and project information shall be submitted to:



2.4.4 Protect all equipment delivered and placed in storage from the weather, excessive humidity and excessive temperature variation, and dirt, dust, or other contaminants. Each heat exchanger shall be separately boxed and crated suitable for shipping and handling with a forklift and/or crane. Lift points shall be clearly marked. The shipping container shall not impart any scratches to paint, be clearly marked and labeled on the exterior of the shipping container with the heat exchanger data for identification and to clearly identify which heat exchanger is the First Stage Cooler; and which is the Second Stage Cooler.

The heat exchanger shall be cleaned and dry prior to shipping. All openings shall be supplied with suitable protective cover to preclude foreign objects or debris from entering the heat exchanger.

2.5 SPARE PARTS

Provide spare parts as indicated below and packaged to protect the parts and include with the shipment of the heat exchanger.

5000 PSI AIR HEAT EXCHANGER
Requirements Document
B1215 Steam Plant Heat-Exchanger

2.5.1 Provide and deliver one set of spare gaskets of each size for the heat exchanger.

3.0 PRODUCTS

3.1 MATERIALS AND EQUIPMENT

3.1.1 Standard Products

Provide all materials, goods, and equipment herein which are new, and the standard products of Original Equipment Manufacturer regularly engaged in the manufacture of such products and that essentially duplicate items. Provide source for spare parts and equipment must be supported by a service organization that is in service area and reasonably convenient to the delivery site.

3.1.2 Nameplates

Place a stainless steel plate on each heat exchanger having the manufacturer's name, address, type or style, model, National board number, serial number, date, performance data, MAWP, MDMT, design temperature, and catalog number permanently secured to the heat exchanger.

3.1.3 Asbestos Prohibition

Asbestos and asbestos-containing products will not be accepted.

3.1.4 Body, Stationary Head, Cover

The heat exchanger body and channel head, if applicable, shall be constructed of ASTM A106 Grade B seamless pipe. The channel cover shall be constructed of forged steel. If applicable, bonnet head shall be constructed of carbon steel.

3.1.5 Body Flanges, Tube Sheet, Tubes

Heat exchanger body flanges shall be forged conforming to ASTM A105 or ASTM A350. Tube sheet material shall conform to ASTM A515 or ASTM A516. Bolt patterns shall be in accordance with ASME B16.5. Tubes shall be seamless carbon steel with a minimum average thickness calculated by Original Equipment Manufacturer for the required process conditions as identified in Appendix A. The decrease in tube thickness due to the bending process shall be accounted for in calculations.

3.1.6 Connections: Hub Connectors, Flanges, Couplings

Tube side inlet and outlet connections shall be carbon steel hub connectors (e.g. Grayloc or Oteco bored for 2" Sch160 pipe). Buttweld hub connectors shall be furnished by the Government.

Shell side inlet and outlet connections shall be Class 300, raised-face, weldneck type flanges conforming to ASTM A105. Flanges must have the manufacturer's trademark and

5000 PSI AIR HEAT EXCHANGER
Requirements Document
B1215 Steam Plant Heat-Exchanger

flange information affixed in accordance with MSS SP-25. Shell coupling material shall conform to ASTM A105 with threads conforming to ASME B1.20.1.

3.1.7 Gaskets

Gaskets must be suitable for pressures and temperatures of the required process conditions as identified in Appendix A.

3.1.8 Studs and Nuts

New studs and nuts shall be provided and comply with ASTM A193 Grade B7, and nuts shall be ASTM A194 Grade 2H. Headed bolts are not allowed. All bolting shall be in compliance with ASME PCC-1. Torque values shall be provided and installation torquing shall be in three steps. Identify wet or dry torque values on drawings.

3.2 HEAT EXCHANGER

3.2.1 Type

Heat exchanger shall be shell and tube, TEMA Type AEU or BEU with a stationary heads and a removable U-tube bundle. The shell shall be provided with extra length to allow for the inlet nozzle to be offset from the end of the tube bundle to avoid direct impingement of steam. Refer to the datasheet in Appendix A for nozzle locations.

3.2.2 General Construction

Heat exchanger must be constructed and tested in accordance with ASME BPVC SEC VIII D1 and certified with a permanent ASME and National Board stamp secured to unit.

Tubes shall be free to expand within shell. Shell shall be of seamless steel pipe. Tube connections to plates must be leakproof. All materials of construction shall be new with no remanufactured parts or materials.

3.2.3 Performance

Heat exchanger shall heat air in the tube side using 125 psig steam on the shell side at the performance requirements as identified in Appendix A. Performance of the heat exchanger shall conform to TEMA standards.

3.2.4 Dimensions

Heat exchangers longer than 6 feet shall be reviewed by NASA.

3.3 SYSTEM EQUIPMENT AND ACCESSORIES

3.3.1 Lifting and Support Systems

Heat exchanger shall be provided with lifting lugs: 2 lugs (minimum) shall be provided for

5000 PSI AIR HEAT EXCHANGER
Requirements Document
B1215 Steam Plant Heat-Exchanger

the shell; if applicable one lug (minimum) shall be provided for each the channel and cover; if applicable, one lug (minimum) shall be provided for the bonnet. Original Equipment Manufacturer shall determine appropriate lug quantity and locations.

Heat exchanger shall be provided with support legs (two minimum) that will allow for bolting down onto structure steel frame members. Original Equipment Manufacturer shall determine appropriate leg quantity and locations.

3.3.2 Vent Connection

Vent (intermediate) connection shall be provided as indicated in APPENDIX A.

3.3.3 Coating/Paint System

Heat exchanger must be coated on its exterior with primer and a final paint system. Both primer and final paint systems shall be suitable for a sustained temperature of 400 degrees F. Color shall be Light Grey. Surface preparation prior to painting shall be White metal blast cleaning: SSPC SP5, NACE No. 1, SA3. Bolts, nuts, flange face, and gaskets shall not be painted. Primer and final paint coating thickness shall be as recommended by the paint manufacturer for the paint system.

4.0 EXECUTION

4.1 Connections

Provide bonnet and shell connections of the size as indicated in APPENDIX A.

4.2 Testing and Cleaning

Submit performance and all test reports to demonstrate compliance with the specified performance criteria for the completed goods.

4.3 Pressure Testing

Hydrostatic testing of the assembled heat exchanger at pressure in accordance with Code shall be completed with clean potable water free of chlorides. Results of test results shall be provided. Leakage allowance is zero. All residual water shall be completely removed after testing. Provide blind flanges and plugs suitable for the pressure and service as required for testing. All test water shall be completely removed.

4.4 Cleaning

Prior to hydrostatic tests, the heat exchanger shall be cleaned of all interior and exterior metal surface oils or metal preservatives, dust, dirt, rust. The Original Equipment Manufacturer will be responsible for maintaining the heat exchanger in a clean condition until delivery of goods at NASA.

5000 PSI AIR HEAT EXCHANGER
Requirements Document
B1215 Steam Plant Heat-Exchanger

APPENDIX A

1. Heat Exchanger Data Sheet

NASA LANGLEY RESEARCH CENTER - HAMPTON, VA

SHELL AND TUBE HEAT EXCHANGER DATA SHEET

1	Facility	B1215 STEAM PLANT	Project No.	JTHEX5000
2	Address	14 W TAYLOR ST, MS 177, HAMPTON, VA 23681	Date	2/5/2026 Rev 0
3	Equipment Tag	HEX-1		
4	Service of Unit	5000 PSI AIR		
5	Size	Note 1 x Note 1 inch	Type	AEU or BEU in Horizontal Connected In N/A Parallel N/A Series
6	Surf/Unit (Gross/Eff)	Note 2 / Note 1 ft2	Shell/Unit	1 Surf/Shell (Gross/Eff) / ft2

PERFORMANCE OF ONE UNIT

Fluid Allocation		Shell Side		Tube Side	
8	Fluid Name	STEAM		AIR	
10	Fluid Quantity, Total lb/hr	414		16840 (3740 SCFM)	
11	Vapor (In/Out) Note 3			16840	16840
12	Liquid				
13	Steam (Saturated)	414			
14	Water/Condensate		414		
15	Noncondensables				
16	Temperature (In/Out)	353	353	60	126.4
17	Specific Gravity			0.324	0.282
18	Viscosity cP	0.015	0.152	0.027	0.027
19	Molecular Weight, Vapor	18		29	
20	Molecular Weight, Noncondensables				
21	Specific Heat Btu/lb-F			0.324	0.305
22	Thermal Conductivity Btu/hr-ft-F			0.026	0.026
23	Latent Heat Btu/lb	869			
24	Inlet Pressure psia		139.7		4264.7
25	Velocity ft/sec				
26	Pressure Drop, Allow/Calc psi	6		3	
27	Fouling Resistance (min) ft2-hr-F/Btu		0.0005		0.001
28	Heat Exchanged	359,900 Btu/hr (Note 3)		MTD (Corrected) F	
29	Transfer Rate, Service	Note 1 Btu/ft2-hr-F	Clean	Btu/ft2-hr-F Actual	Btu/ft2-hr-F

CONSTRUCTION OF ONE SHELL

Sketch (Bundle/Nozzle Orientation)

		Shell Side	Tube Side	See Page 2 of this data sheet.
32	Design/Test Pressure psig	635	5000	
33	Design Temperature (MDMT) F	400 (-20)	400 (-20)	
34	No Passes per Shell	1	2	
35	Corrosion Allowance inch	0.0625	0.0625	
36	Connections In inch	4" Class 300	2" Hub Connector	
37	Size & Out inch	4" Class 300	2" Hub Connector	
38	Rating Intermediate	3/4" 3000# FNPT		

39	Tube No. Note 1	OD Note 1 inch	Thk(Avg) Note 1 inch	Length Note 1 ft	Pitch Note 1 inch
40	Tube Type	Plain, Seamless	Material	Carbon Steel	Tube pattern Note 1
41	Shell/Flanges	A106 Grade B / ASTM A105 or ASTM A350		Shell Cover	Carbon Steel
42	Channel or Bonnet	A106 Grade B / Carbon Steel		Channel Cover	Forged Carbon Steel
43	Tubesheet-Stationary	ASTM A515 or ASTM A516		Tubesheet-Floating	
44	Floating Head Cover			Impingement Plate	Note 1
45	Baffles-Cross	Carbon Steel			
46	Baffles-Long		Seal Type	N/A	
47	Supports-Tube	Carbon Steel	U-Bend		Type
48	Bypass Seal Arrangement	N/A	Tube-Tubesheet Joint	Note 1	
49	Expansion Joint	N/A	Type	N/A	
50					
51	Gaskets-Shell Side	Note 1	Tube Side	Note 1	
52	-Floating Head	N/A			
53	Code Requirements	ASME Section VIII Division 1		TEMA Class	Note 1
54					

55 Remarks:

56 Note 1: Calculated or determined by manufacturer.

57 Note 2: Manufacturer shall provide a minimum of 15% in excess of effective area.

58 Note 3: Manufacturer shall verify all fluid properties and heat exchanged.

59 Note 4: Hub connectors are bored for Sch 160 pipe.

60 Note 5: Refer to the associated requirements document for additional information.

SHELL AND TUBE HEAT EXCHANGER DATA SHEET

1	Facility	B1215 STEAM PLANT	Project No.	JTHEX5000	
2	Address	14 W TAYLOR ST, MS 177, HAMPTON, VA 23681	Date	2/5/2026	Rev 0
3	Equipment Tag	HEX-1			
4	Service of Unit	5000 PSI AIR			

Concept of Heat Exchanger

